

## Declaration of Test Results

*BSI Product Services hereby declares that the item described below has been tested by BSI and complies with the requirements of*

BS EN 61386-21:2004 Clauses 8, 9, 10.7, 11.2, 14.1 and 14.2


*The complete detail of the tests performed and the results are recorded in BSI Test Report No: 2867226597 Dated: 5 September 2008*

*Description of item tested:* 20mm diameter steel conduit with steel terminal boxes and couplers  
25mm diameter steel conduit with steel terminal boxes and couplers

*Submitted by:* Demon Cato Limited  
10 Dryden Road  
Bilston Glen Industrial Estate  
Edinburgh  
EH20 9LZ

*Declaration authorised by:*

G R Essam



*Title*

*Principal Engineer*

*Date*

*5<sup>th</sup> September 2008*

Attention is drawn to the conditions upon which this declaration is issued, namely:

1. This declaration does not indicate provide or imply any measure of Approval, Certification, Supervision, Control or Surveillance by BSI to this or any related product.
2. This Declaration applied only to the particular sample tested and to the specific tests carried out as detailed in the Report referred to above.
3. The general and specific conditions of the BSI Product Services, PC082 apply in all respects. Copies of this leaflet are available on request.